

FB3 - <offline>

"Process_level"

Name:	Family:
Author:	Version: 0.1
	Block version: 2
Time stamp Code:	12.03.02 13:58:07
Interface:	18.06.01 11:45:03
Lengths (block/logic/data):	00144 00042 00000


Address	Declaration	Name	Type	Initial value	Comment
	in				
	out				
	in_out				
0.0	stat	MD138	REAL	0.000000e+000	
4.0	stat	MD142	REAL	0.000000e+000	
	temp				

Block: FB3 Level measuring

Measuring if there are enough water in the tanks.

Network: 1 Comparison

Comparing the level with the minimums-value.



Symbol information

MD142	Level1+level2	Summerte level values
M0.4	Level_low	


Network: 2 Lamp on cabinet, Level too low.



Symbol information

M0.4	Level_low	
Q37.0	-H8	Signal lamp for low level

Network: 3 Calculating the level




Symbol information

MD146	Level1	Level
MD138	Level1_2	Level1 delt på 2

Network: 4

Calculating the level



Symbol information		
MD124	Level2	Level2
MD138	Level1_2	Level1 delt på 2
MD142	Level1+level2	Summerte level values